

# TYPE APPROVAL CERTIFICATE

**This is to certify:**

**That the Electric Actuator**

with type designation(s)  
**QT250/800 2.5 CANopen Actuator,**  
**QT250/800 2.5 Digital/Analog Actuator,**  
**QT250/800 2.5 CANopen Failsafe Actuator**

Issued to

**Eltorque AS**  
**Vanvikan, Norway**

is found to comply with  
**DNV GL rules for classification – Ships, offshore units, and high speed and light craft**

**Application :**

**Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.**

**Location classes:**

Type	Temp.	Humidity	Vibration	EMC	Enclosure
QT250/800 2.5 CANopen Actuator	D	B	A	A	C/D
QT250/800 2.5 Digital/Analog Actuator	D	B	A	A	C/D
QT250/800 2.5 CANopen Failsafe Actuator	A	B	A	A	C/D

Issued at **Høvik** on **2018-05-15**

for **DNV GL**

This Certificate is valid until **2023-05-14**.

DNV GL local station: **Trondheim**

Approval Engineer: **Jens Erling Bråten**

.....  
**Odd Magne Nesvåg**  
**Head of Section**

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.



## Product description

This certificate covers the following components:

Article number	Description	Comments
250.120.5A	QT250 2.5 CANopen Actuator	
250.120.5AH	QT250 2.5 CANopen Actuator	Suits the hybrid marine cable
250.150.5A	QT250 2.5 Digital/Analog Actuator	
250.120.5B	QT250 2.5 CANopen Failsafe Actuator	
250.120.5BH	QT250 2.5 CANopen Failsafe Actuator	Suits the hybrid marine cable

Article numbers and description, QT250

Article number	Description	Comments
800.120.5A	QT800 2.5 CANopen Actuator	
800.120.5AH	QT800 2.5 CANopen Actuator	Suits the hybrid marine cable
800.150.5A	QT800 2.5 Digital/Analog Actuator	
800.120.5B	QT800 2.5 CANopen Failsafe Actuator	
800.120.5BH	QT800 2.5 CANopen Failsafe Actuator	Suits the hybrid marine cable

Article numbers and description, QT800

## Approval conditions

The Type Approval covers hardware listed under Product description. When the hardware is used in applications to be classed by DNV GL, documentation for the actual application is to be submitted for approval by the manufacturer of the application system in each case. Reference is made to DNV GL rules for classification of ships Pt.4 Ch.9 Control and monitoring systems.

### Product certificate

If specified in the Rules, ref. Pt.4 Ch.9 Sec.1, the control and monitoring system in which the above listed hardware is used shall be delivered with a product certificate. For each such delivery the certification test is to be performed at the manufacturer of the application system before the system is shipped to the yard. The test shall be done according to an approved test program. After certification the clause for software control will be put into force.

### Software control

All changes in software are to be recorded as long as the system is in use on board. Documentation of major changes is to be forwarded to DNV GL for evaluation and approval before implemented on board. Certification of modified functionality may be required for the particular vessel.

## Type Approval documentation

Type test of application functions, doc. No 2053/DNV, rev.1.0, dated 2018-02-06

Type approval notes - Gen 2\_5 & Failsafe actuators, doc. No 23921959/DNV, rev.1.0, dated 2018-03-16

E17134.02 - Test Report - Nemko - Gen 2\_5, doc. No. 23921966/DNV, Rev.02, dated 2018-05-04

E18015.00 - Test Report - Nemko - Failsafe, doc. No. 23921971/DNV, rev.00, dated 2018-03-09

Type Approval Assessment report, DNV GL Trondheim, dated 2018-02-27

## Tests carried out

Testing in accordance with DNVGL-CG-0339, edition November 2016.

Tested for IP6x, IPx6 and IPx8 (down to 10m for 100h) according to IEC 60529:2013 and IEC 60945:2012.

Job Id: **262.1-027883-1**  
Certificate No: **TAA00001U4**

### **Periodical assessment**

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE